



OIML Member state
The Netherlands

OIML Certificate N° R60/2000-NL1-08.10 Revision 1
Project number 710915
Page 1 of 2

OIML CERTIFICATE OF CONFORMITY

Issuing authority

Name: NMI Certin B.V.
Address: Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
Person responsible: Ing. C. Oosterman

Applicant

Name: Keli Electric Manufacturing (Ningbo) Co., Ltd.
Address: No. 199 Changxing Road,
Jiangbei District, Ningbo,
P.R. China

Manufacturer of the certified type

Name: Keli Electric Manufacturing (Ningbo) Co., Ltd.
Address: No. 199 Changxing Road,
Jiangbei District, Ningbo,
P.R. China

Identification of certified type

A double ended shear beam load cell
Type : QSB....
Fraction : $P_1 = 0.7$
Temperature range $-10\text{ °C} / +40\text{ °C}$
For specifications, see page 2.

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report, the test certificate and the description with number TC7484 and the appertaining documentation folder) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R60
Edition 2000 (E)
for accuracy class C

NMI Certin BV
Hugo de Grootplein 1, 3314 EG Dordrecht
PO Box 394, 3300 AJ Dordrecht, NL
T +31 78 6332332
F +31 78 6332309
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

Reproduction of the complete document is permitted.
The notification of NMI Certin as Issuing Authority can be verified at www.oiml.org.





This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated Test Report:
N° R60/2000-NL1-08.10 that includes 40 pages.

This revision replaces the earlier version.

The Issuing Authority NL1
NMI Certin, 16 November 2009



C. Oosterman
Head Certification Board

*
* *

Load cell specifications:

Type	QSB....
Maximum capacity (E_{max})	22 t up to and including 110 t
Humidity Class	CH
Accuracy Class	C
Maximum number of load cell intervals (n)	2000
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	10000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	2000

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report is not permitted, although either may be reproduced in full.